

RRCC Monument Sign

Project No. C17A0013

Addendum Number One September 26, 2016

Contractors shall acknowledge Addendum One on the Bid Form, SBP-6.13

Answers to Contractor Questions:

1. Powder coating is specified for part of the sign, the applicator of the powder coating will only offer a 1 year warranty on workmanship, there is no warranty on the powder coating. Will an acrylic paint with a five year warranty that matches the powder coating be acceptable? **Yes, acrylic paint is an acceptable alternate.**
2. What is the voltage and amperage of the existing power at the location? **120/240 volt, 50 amp, single phase**
3. Will RRCC connect the primary power to the sign or will the final connection be handled by the sign company? **Yes, RRCC will perform.**
4. Will a tax exempt certificate be provided? **Yes**
5. Do to the custom nature of the monument sign could the bid date be extended? **The bid date is extended to September 30, 2016 3:00 p.m. (Mountain Time)**

End of Addendum Number One