



01/15/2026

RED ROCKS
COMMUNITY COLLEGE

13300 W 6TH AVE
LAKEWOOD, CO 80228

PROJECT TITLE:
FIRE SCIENCE RTU
REPLACEMENT
PROJECT

MARK	DATE	DESCRIPTION
	1/15/26	FOR CONST.

Project Number: -
Drawn By: HDK
Checked By: KLA

SHEET TITLE: MECHANICAL VENTILATION CALCULATIONS

RTU-1 Outside Air Ventilation Calculation														
ELITE ZONE NO.	ZONE DESCRIPTION	OCCUPANCY CLASSIFICATION	PEOPLE OUTDOOR AIRFLOW RATE IN BREATHING ZONE (CFM/PERSON)	AREA OUTDOOR AIRFLOW RATE IN BREATHING ZONE (CFM/FT²)	OCCUPANT DENSITY (PEOPLE / 1,000 S.F.)	ZONE AREA (FT²)	NUMBER OF PEOPLE IN BREATHING ZONE	CALCULATED PEOPLE OUTDOOR AIR VOLUME (CFM)	CALCULATED AREA OUTDOOR AIR VOLUME (CFM)	ZONE DISTRIBUTION EFFECTIVENESS	TOTAL CALCULATED OUTDOOR AIR REQUIRED (CFM)	OA % OF TOTAL SA	TOTAL OUTSIDE AIR PROVIDED (CFM)	
1	CLASSROOM	Classroom 9+ yrs	10.0	0.12	35.0	680.0	24.0	240.0	81.6	0.8	402.0	25.0%	402.5	
2	HALLWAY	Corridor	0.0	0.06	0.0	740.0	0.0	0.0	44.4	0.8	55.5	25.0%	56.3	
3	CONFERENCE	Conference	5.0	0.06	50.0	262.0	14.0	70.0	15.7	0.8	107.2	25.0%	107.5	
4	RESTROOM	Toilet	0.0	0.00	0.0	100.0	0.0	0.0	0.0	0.8	0.0	25.0%	1.3	
Occupancy based on ARCH Floorplans where applicable.												564.7	567.5	

RTU-2 Outside Air Ventilation Calculation														
ELITE ZONE NO.	ZONE DESCRIPTION	OCCUPANCY CLASSIFICATION	PEOPLE OUTDOOR AIRFLOW RATE IN BREATHING ZONE (CFM/PERSON)	AREA OUTDOOR AIRFLOW RATE IN BREATHING ZONE (CFM/FT²)	OCCUPANT DENSITY (PEOPLE / 1,000 S.F.)	ZONE AREA (FT²)	NUMBER OF PEOPLE IN BREATHING ZONE	CALCULATED PEOPLE OUTDOOR AIR VOLUME (CFM)	CALCULATED AREA OUTDOOR AIR VOLUME (CFM)	ZONE DISTRIBUTION EFFECTIVENESS	TOTAL CALCULATED OUTDOOR AIR REQUIRED (CFM)	OA % OF TOTAL SA	TOTAL OUTSIDE AIR PROVIDED (CFM)	
1	OFFICE	Office	5.0	0.06	5.0	160.0	1.0	5.0	9.6	0.8	18.3	25.0%	26.3	
2	HALLWAY	Corridor	0.0	0.06	0.0	115.0	0.0	0.0	6.9	0.8	8.6	25.0%	13.8	
3	LOBBY	Main Entry Lobbies	5.0	0.06	10.0	885.0	9.0	45.0	53.1	0.8	122.6	25.0%	123.8	
4	RESTROOM	Toilet	0.0	0.00	0.0	361.0	0.0	0.0	0.0	0.8	0.0	25.0%	26.3	
Occupancy based on ARCH Floorplans where applicable.												149.5	190.0	

RTU-3 Outside Air Ventilation Calculation														
ELITE ZONE NO.	ZONE DESCRIPTION	OCCUPANCY CLASSIFICATION	PEOPLE OUTDOOR AIRFLOW RATE IN BREATHING ZONE (CFM/PERSON)	AREA OUTDOOR AIRFLOW RATE IN BREATHING ZONE (CFM/FT²)	OCCUPANT DENSITY (PEOPLE / 1,000 S.F.)	ZONE AREA (FT²)	NUMBER OF PEOPLE IN BREATHING ZONE	CALCULATED PEOPLE OUTDOOR AIR VOLUME (CFM)	CALCULATED AREA OUTDOOR AIR VOLUME (CFM)	ZONE DISTRIBUTION EFFECTIVENESS	TOTAL CALCULATED OUTDOOR AIR REQUIRED (CFM)	OA % OF TOTAL SA	TOTAL OUTSIDE AIR PROVIDED (CFM)	
1	CLASSROOM	Classroom 9+ yrs	10.0	0.12	35.0	1,630.0	58.0	580.0	195.6	0.8	969.5	30.0%	970.5	
2	HALLWAY	Corridor	0.0	0.06	0.0	450.0	0.0	0.0	27.0	0.8	33.8	30.0%	34.5	
Occupancy based on ARCH Floorplans where applicable.												1,003.3	1,005.0	

RTU-4 Outside Air Ventilation Calculation														
ELITE ZONE NO.	ZONE DESCRIPTION	OCCUPANCY CLASSIFICATION	PEOPLE OUTDOOR AIRFLOW RATE IN BREATHING ZONE (CFM/PERSON)	AREA OUTDOOR AIRFLOW RATE IN BREATHING ZONE (CFM/FT²)	OCCUPANT DENSITY (PEOPLE / 1,000 S.F.)	ZONE AREA (FT²)	NUMBER OF PEOPLE IN BREATHING ZONE	CALCULATED PEOPLE OUTDOOR AIR VOLUME (CFM)	CALCULATED AREA OUTDOOR AIR VOLUME (CFM)	ZONE DISTRIBUTION EFFECTIVENESS	TOTAL CALCULATED OUTDOOR AIR REQUIRED (CFM)	OA % OF TOTAL SA	TOTAL OUTSIDE AIR PROVIDED (CFM)	
1	CLASSROOM	Classroom 9+ yrs	10.0	0.12	35.0	1,642.0	58.0	580.0	197.0	0.8	971.3	34.0%	972.4	
2	HALLWAY	Corridor	0.0	0.06	0.0	345.0	0.0	0.0	20.7	0.8	25.9	34.0%	27.2	
Occupancy based on ARCH Floorplans where applicable.												997.2	999.6	

RTU-5 Outside Air Ventilation Calculation														
ELITE ZONE NO.	ZONE DESCRIPTION	OCCUPANCY CLASSIFICATION	PEOPLE OUTDOOR AIRFLOW RATE IN BREATHING ZONE (CFM/PERSON)	AREA OUTDOOR AIRFLOW RATE IN BREATHING ZONE (CFM/FT²)	OCCUPANT DENSITY (PEOPLE / 1,000 S.F.)	ZONE AREA (FT²)	NUMBER OF PEOPLE IN BREATHING ZONE	CALCULATED PEOPLE OUTDOOR AIR VOLUME (CFM)	CALCULATED AREA OUTDOOR AIR VOLUME (CFM)	ZONE DISTRIBUTION EFFECTIVENESS	TOTAL CALCULATED OUTDOOR AIR REQUIRED (CFM)	OA % OF TOTAL SA	TOTAL OUTSIDE AIR PROVIDED (CFM)	
1	OFFICES	Office	5.0	0.06	5.0	2,076.0	11.0	55.0	124.6	0.8	224.5	25.0%	225.0	
2	CLASSROOM	Classroom 9+ yrs	10.0	0.12	35.0	824.0	29.0	290.0	98.9	0.8	486.1	25.0%	486.3	
3	LOBBY	Main Entry Lobbies	5.0	0.06	10.0	616.0	7.0	35.0	37.0	0.8	90.0	25.0%	90.0	
4	HALLWAY	Corridor	0.0	0.06	0.0	1,965.0	0.0	0.0	117.9	0.8	147.4	25.0%	147.5	
Occupancy based on ARCH Floorplans where applicable.												947.9	948.8	



Compliance Certificate

Project Information

Energy Code: 2024 IECC
Project Title: Red Rocks Community College
Location: Lakewood, Colorado
Climate Zone: 5b
Project Type: Alteration
Project Sub Type: Initial Buildout
Project Mechanical Type: All Electric
Is Renewable: false
Has Battery: false
Has Charger: false
Has Heat Pump: false

Construction Site: Owner/Agent: Designer/Contractor:

Mechanical Systems List

Quantity	Component	Description
3	RTU-1.4.7 (Single Zone):	Heating: 1 each - Central Furnace (Heating Equip), Gas, Capacity = 224 kBtuh Proposed Efficiency = 80.00 % Et, Required Efficiency: 80.00 % Et or 80% AFUE Cooling: 1 each - Single Package DX Unit (Cooling Equip), Capacity = 90 kBtuh, Air-Cooled Condenser, Air Economizer Proposed Efficiency = 14.60 IEEER, Required Efficiency = 14.60 IEEER Proposed Part Load Efficiency = 0.00, Required Part Load Efficiency = 0.00 Fan System: FAN 1 - Compliance (Motor nameplate HP and fan efficiency method) : Passes Fan: Fan Supply, Single-Zone VAV, 3000 CFM, 3.0 motor nameplate hp, 1.00 fan energy index
1	RTU-2.3 (Single Zone):	Heating: 1 each - Central Furnace (Heating Equip), Gas, Capacity = 224 kBtuh Proposed Efficiency = 80.00 % Et, Required Efficiency: 80.00 % Et or 80% AFUE Cooling: 1 each - Single Package DX Unit (Cooling Equip), Capacity = 100 kBtuh, Air-Cooled Condenser, Air Economizer Proposed Efficiency = 14.60 IEEER, Required Efficiency = 14.60 IEEER Proposed Part Load Efficiency = 0.00, Required Part Load Efficiency = 0.00 Fan System: FAN 2 - Compliance (Motor nameplate HP and fan efficiency method) : Passes Fan: Fan Supply, Single-Zone VAV, 3400 CFM, 3.0 motor nameplate hp, 1.00 fan energy index
1	RTU-5.8 (Single Zone):	Heating: 1 each - Central Furnace (Heating Equip), Gas, Capacity = 250 kBtuh Proposed Efficiency = 81.00 % Et, Required Efficiency: 81.00 % Et or 80% AFUE Cooling: 1 each - Single Package DX Unit (Cooling Equip), Capacity = 141 kBtuh, Air-Cooled Condenser, Air Economizer Proposed Efficiency = 14.00 IEEER, Required Efficiency = 14.00 IEEER Proposed Part Load Efficiency = 0.00, Required Part Load Efficiency = 0.00 Fan System: FAN 3 - Compliance (Motor nameplate HP and fan efficiency method) : Passes Fan: Fan Supply, Single-Zone VAV, 5000 CFM, 5.0 motor nameplate hp, 1.00 fan energy index
1	RTU-6 (Single Zone):	Heating: 1 each - Central Furnace (Heating Equip), Gas, Capacity = 110 kBtuh Proposed Efficiency = 80.00 % Et, Required Efficiency: 80.00 % Et or 80% AFUE Cooling: 1 each - Single Package DX Unit (Cooling Equip), Capacity = 33 kBtuh, Air-Cooled Condenser, Air Economizer Proposed Efficiency = 13.40 SEER2, Required Efficiency = 13.40 SEER2 Proposed Part Load Efficiency = 0.00, Required Part Load Efficiency = 0.00 Fan System: FAN 4 - Compliance (Motor nameplate HP and fan efficiency method) : Passes Fan: Fan Supply, Single-Zone VAV, 1200 CFM, 1.5 motor nameplate hp, 1.00 fan energy index

Renewable energy

Number of Floors: 1
Area of Three Largest Floors: 0
Proposed Capacity: 0
Required Capacity: 0
Proposed Off-site Energy: 0
Required Off-site Energy: 0
Exception: None

Renewables Pass

Building Area

Description **Floor Area**

Report Title: Red Rocks Community College Report Date: 1/14/26, 3:29 PM 1 of 12 Report Title: Red Rocks Community College Report Date: 1/14/26, 3:29 PM 2 of 12 Report Title: Red Rocks Community College Report Date: 1/14/26, 3:29 PM 3 of 12 Report Title: Red Rocks Community College Report Date: 1/14/26, 3:29 PM 4 of 12 Report Title: Red Rocks Community College Report Date: 1/14/26, 3:29 PM 5 of 12 Report Title: Red Rocks Community College Report Date: 1/14/26, 3:29 PM 6 of 12 Report Title: Red Rocks Community College Report Date: 1/14/26, 3:29 PM 7 of 12

Section # & Req.ID	Mechanical Rough-In Inspection	Complies?	Comments/Assumptions
C403.4.8.2 [ME39]	Humidity controls do not use fossil fuel or electricity for a humidity > 30% in warmest zone.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.4.8.3 [ME39]	Zones served by systems with both humidification and dehumidification prevent simultaneous operation.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.5.1, C403.5.2 [ME39]	Air economizers provided where required, control the system to prevent a high-limit shut-off, integrated economizer control, and provide a means to relieve excess outside air during operation.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.5.2 [ME40]	Economizer operation will not increase heating energy use during normal operation.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.5.3.3 [ME41]	Air economizers automatically reduce outdoor air intake to the design minimum outdoor air quantity when outdoor air intake is greater than 10% of total energy usage. See Table C403.5.3.3 for applicable device types and climate zones.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.5.3.4 [ME42]	System capable of reducing excess outdoor air during air economizer operation to prevent over pressurizing the building. The system is located to avoid recirculation into the building.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.5.5 [ME43]	Return, exhaust/reject and outdoor air dampers used in economizers have independent control and automatically shut when not in use and meet maximum leakage rates. Reference section C403.7.7 for details.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.5.6 [ME45]	Fault detection and diagnostics installed with air-cooled unitary DX units or VRF units having economizers.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.7.1 [ME56]	Demand control ventilation provided for spaces >250 G and <15 people/100 ft ² occupant density and served by system with air side economizer, auto modulating outside air damper, motor, or design airflow >3,000 cfm.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.7.2 [ME57]	Enclosed parking garage ventilation has separate ventilation systems for each section, can reduce airflow <0.05 cfm/sq ft of floor area and >20% of design capacity.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.7.4 [ME59]	Exhaust air energy recovery on systems meeting Table C403.7.4(1) and C403.7.4(2).	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

Mechanical Compliance Certificate

Project Information

Energy Code: 2024 IECC
Project Title: Red Rocks Community College
Location: Lakewood, Colorado
Climate Zone: 5b
Project Type: Alteration
Project Sub Type: Initial Buildout
With Central HVAC/SWH/Plant

Construction Site: Owner/Agent: Designer/Contractor:

Mechanical Systems List

Quantity	Component	Description
3	RTU-1.4.7 (Single Zone):	Heating: 1 each - Central Furnace (Heating Equip), Gas, Capacity = 224 kBtuh Proposed Efficiency = 80.00 % Et, Required Efficiency: 80.00 % Et or 80% AFUE Cooling: 1 each - Single Package DX Unit (Cooling Equip), Capacity = 90 kBtuh, Air-Cooled Condenser, Air Economizer Proposed Efficiency = 14.60 IEEER, Required Efficiency = 14.60 IEEER Proposed Part Load Efficiency = 0.00, Required Part Load Efficiency = 0.00 Fan System: FAN 1 - Compliance (Motor nameplate HP and fan efficiency method) : Passes Fan: Fan Supply, Single-Zone VAV, 3000 CFM, 3.0 motor nameplate hp, 1.00 fan energy index
1	RTU-2.3 (Single Zone):	Heating: 1 each - Central Furnace (Heating Equip), Gas, Capacity = 224 kBtuh Proposed Efficiency = 80.00 % Et, Required Efficiency: 80.00 % Et or 80% AFUE Cooling: 1 each - Single Package DX Unit (Cooling Equip), Capacity = 100 kBtuh, Air-Cooled Condenser, Air Economizer Proposed Efficiency = 14.60 IEEER, Required Efficiency = 14.60 IEEER Proposed Part Load Efficiency = 0.00, Required Part Load Efficiency = 0.00 Fan System: FAN 2 - Compliance (Motor nameplate HP and fan efficiency method) : Passes Fan: Fan Supply, Single-Zone VAV, 3400 CFM, 3.0 motor nameplate hp, 1.00 fan energy index
1	RTU-5.8 (Single Zone):	Heating: 1 each - Central Furnace (Heating Equip), Gas, Capacity = 250 kBtuh Proposed Efficiency = 81.00 % Et, Required Efficiency: 81.00 % Et or 80% AFUE Cooling: 1 each - Single Package DX Unit (Cooling Equip), Capacity = 141 kBtuh, Air-Cooled Condenser, Air Economizer Proposed Efficiency = 14.00 IEEER, Required Efficiency = 14.00 IEEER Proposed Part Load Efficiency = 0.00, Required Part Load Efficiency = 0.00 Fan System: FAN 3 - Compliance (Motor nameplate HP and fan efficiency method) : Passes Fan: Fan Supply, Single-Zone VAV, 5000 CFM, 5.0 motor nameplate hp, 1.00 fan energy index
1	RTU-6 (Single Zone):	Heating: 1 each - Central Furnace (Heating Equip), Gas, Capacity = 110 kBtuh Proposed Efficiency = 80.00 % Et, Required Efficiency: 80.00 % Et or 80% AFUE Cooling: 1 each - Single Package DX Unit (Cooling Equip), Capacity = 33 kBtuh, Air-Cooled Condenser, Air Economizer Proposed Efficiency = 13.40 SEER2, Required Efficiency = 13.40 SEER2 Proposed Part Load Efficiency = 0.00, Required Part Load Efficiency = 0.00 Fan System: FAN 4 - Compliance (Motor nameplate HP and fan efficiency method) : Passes Fan: Fan Supply, Single-Zone VAV, 1200 CFM, 1.5 motor nameplate hp, 1.00 fan energy index

Mechanical Compliance Statement

Compliance Statement: The proposed mechanical design represented in this document is consistent with the building plans, specifications, and other calculations submitted with the permit application. The proposed mechanical systems have been designed to meet the 2024 IECC requirements in COMcheckWeb and to comply with any applicable mandatory requirements listed in the Inspection Checklist.

HUNTER KEPON - P.E.

1/14/2026

Name - Title

Signature

Date

Inspection Checklist

Energy Code: 2024 IECC

Requirements: All were addressed directly in the COMcheck software. Text in the "Comments/Assumptions" column is provided by the user in the COMcheck Requirements screen. For each requirement, the user certifies that a code requirement will be met and how that is documented, or that an exception is being claimed. Where compliance is itemized in a separate table, a reference to that table is provided.

Plan Review

Section # & Req.ID	Plan Review	Complies?	Comments/Assumptions
C403.10.2 [PH2]	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the mechanical and service water heating systems and document where exceptions to the standard are claimed. List of required plans, specifications, and engineering standards and handbooks. Hot water system sized per manufacturer's sizing guide.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

Additional Comments/Assumptions:

1	High Impact (Tier 1)	2	Medium Impact (Tier 2)	3	Low Impact (Tier 3)
---	----------------------	---	------------------------	---	---------------------

Mechanical Rough-In Inspection

Section # & Req.ID	Mechanical Rough-In Inspection	Complies?	Comments/Assumptions
C403.3 [ME1]*	HVAC equipment efficiency verified.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Mechanical Systems list for values
C403.12.3, C403.12.1, C403.12.2 [ME13]*	Refrigerated display cases, walk-in coolers or walk-in freezers served by remote compressors not located in a condensing unit, have fan coil units with remote compressors and meet Sections C403.12.1 and refrigeration compressor systems that comply with C403.12.2.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.14.1 [ME14]*	Systems that heat outside the building envelope are radiant heat systems controlled by an occupancy sensing device or timer switch.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.13.1, C403.13.2 [ME15]*	HVAC ducts and plenums insulated in accordance with C403.13. and C403.13.2, verification may need to occur during Foundation Inspection.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.2.2 [ME16]*	Natural or mechanical ventilation is provided in accordance with International Mechanical Code Chapter 4. Mechanical ventilation has capacity to reduce outdoor air supply to minimum per MAC Chapter 4.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.3.3 [ME20]*	Hot gas bypass limited to: <-240 kBtu/h - 50% >240 kBtu/h - 25%	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.4.1.3 [ME24]*	Where thermostatic control setpoints are adjustable by occupants or HVAC independent for heating and cooling setpoints.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.4.1.5 [ME26]*	Heating for vestibules and air curtains with integrated controls including automatic controls of the heating system when outdoor air temperatures > 45F. Vestibule setpoint < 60F and cooling setpoint > 60F and a thermostat in the vestibule with heating setpoint < 60F and cooling setpoint > 60F.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.9 [ME33]	Large diameter fans when installed shall be tested and labeled in accordance with AMCA 230 and meet efficiency requirements of Table C403.9.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.4.7 [ME35]*	Doors or operable openings from common areas shall be closed so as to not interfere with automatic controls interlocked with the heating and cooling system.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.4.8.1 [ME36]*	Dehumidification controls do not use mechanical cooling to reduce humidity < 60% or a dew point < 55F.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

Section # & Req.ID	Mechanical Rough-In Inspection	Complies?	Comments/Assumptions
C403.7.5 [ME30]	Kitchen exhaust systems comply with replacement air and conditioned supply air limitations, air safety hold rating and minimum air flow rate criteria. Type I exhaust hoods contain controls to prevent ventilation with > 50% reduced exhaust air.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.7.6 [ME51]*	HVAC systems serving guestrooms in Group R-1 buildings with 50 guestrooms. Each guestroom is provided with a minimum air change rate and a minimum temperature setpoint and ventilation (see sections C403.7.6.1 and C403.7.6.2).	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.7.8, C403.7.8.1 [ME50]*	Classrooms, training rooms, conference and multipurpose rooms, lobbies, entrance areas, office areas and corridors contain occupied standby ventilation controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.8.4 [ME57]*	Motors for fans that are not less than 1/12 hp and not greater than 1/2 hp, commercial motors or have a minimum motor efficiency of 70 percent. These motors have the means to adjust motor speed.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.8.6 [ME50]*	Each DX cooling system - 60 kBtu and chiller water/evaporative cooling system with fans > 14 hp are designed to vary the fan speed as a function of load and comply with detailed requirements of this section.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.15 [ME59]*	Dehumidification systems for plant growth and maintenance are tested in accordance with DOE 10 CFR 430, has on-site heat recovery system, and has a minimum dehumidification energy or has a solid or liquid desiccant.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.16 [ME70]*	Service water pressure boost systems contain pressure sensors for pump control, and the pump and pressure boosters do not operate when there is no service water flow.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.17 [ME71]*	Clean water pumps achieve a pump energy index (PE) <= 1.0.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C408.2.2.1 [ME73]*	Air outlets and zone terminal devices have means for air balancing.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.1.1 [ME75]	Enclosed parking garage ventilation has separate ventilation systems for each section, can reduce airflow <0.05 cfm/sq ft of floor area and >20% of design capacity.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.7.4 [ME59]*	Exhaust air energy recovery on systems meeting Table C403.7.4(1) and C403.7.4(2).	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not Comply <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

Section # & Req.ID	Rough-In Electrical Inspection	Complies?	Comments/Assumptions
C405.7 [EL3]*	Low-voltage dry-type distribution electric transformers meet the minimum		

RED ROCKS COMMUNITY COLLEGE

3300 W 61ST AVE
LAKEWOOD, CO 80228

TITLE:

SCIENCE RTU

PLACEMENT

PROJECT

Project Number: -
Drawn By: HDK
Checked By: KLA


SHEET TITLE:

MECHANICAL COMCHECK

GENERAL NOTES


1. CONTRACTOR SHALL NOT SHUT-OFF/PUT OUT SERVICE ANY SYSTEMS/SERVICES WITHOUT FIRST COORDINATING WITH OWNER.
2. CONTRACTOR IS RESPONSIBLE FOR FIELD VERIFICATION OF ALL EXISTING CONDITIONS PRIOR TO THE COMMENCEMENT OF ANY WORK AND SHALL NOTIFY THE ENGINEER OF ANY DISCREPANCIES FOR RESOLUTIONS.
3. IN THE EVENT THAT THE CONTRACTOR ENCOUNTERS HAZARDOUS MATERIALS OR CONDITIONS, THE CONTRACTOR SHALL CEASE ALL WORK IMMEDIATELY AND CONTACT THE OWNER/ENGINEER.
4. PIPES REMOVED SHALL HAVE HANGERS AND SUPPORTS REMOVED COMPLETELY.

LEGEND

 HATCHED EQUIPMENT TO BE REMOVED.

DEMOLITION KEY NOTES

1. DISCONNECT (E) GAS LINE TO BE RECONNECTED TO (N) RTU.
2. (N) CURB ADAPTER TO BE PLACED ON (E) CURB.
3. (E) CURB TO REMAIN.
4. PRE-READ (E) SA CFM BEFORE DEMO. BALANCE (N) RTU TO MATCH (E) SA CFM.



01/15/2026

**RED ROCKS
COMMUNITY COLLEGE**

13300 W 6TH AVE
LAKEWOOD, CO 80228


PROJECT TITLE:
**FIRE SCIENCE RTU
REPLACEMENT
PROJECT**

MARK	DATE	DESCRIPTION
	1/15/26	FOR CONST.


Project Number: -
Drawn By: HDK
Checked By: KLA

SHEET TITLE:

**MECHANICAL
DEMOLITION PLAN**



M1.0





MC+ ENGINEERING, LLC 8421 STACY DRIVE, FEDERAL HEIGHTS, CO 80260 (P) 303.589.6202															
480/277 VOLTS 3 PHASE, 4 WIRE PANEL			H3G			150 AMPS									
SURFACE		FLUSH	TYPE		EATON		AIC		14,000						
<input checked="" type="checkbox"/> EXISTING <input type="checkbox"/> NEW <input type="checkbox"/> M.C.B. <input type="checkbox"/> 150A3P MAX ALLOWED THIS PNL															
<input checked="" type="checkbox"/> VOLT AMPS CCT BKR A B C															
DESCRIPTION															
CRANE HOIST	20	1	2	100	7	1	2	1	PANEL 150A3P						
	2768	3	4	1500	7	3	4	2	75KVA TRANSFORMER						
	2768	3	5	1500	7	3	6	2							
SPECIAL OUTLET	2076	15	7	8	60	8	10	8	A/C: esha class room						
CL19.CMU-1	2076	9	10	8304	9	10	8	8							
CL19.C/SOUTH	2076	15	11	12	3	12	12	12							
"MUA"	2076	15	12	50	7750	15	12	12	"RTU-8"						
	2076	15	15	16	7750	15	16	16							
	2076	3	17	18	3	17	18	18	7750						
	2076	18	20												
	21	22													
	23	24													
	25	26													
	27	28													
	29	30													
	31	32													
	33	34													
	35	36													
	37	38													
	39	40													
	41	42													
CONNECTED KVA															
LIGHTING	0.0	125	0.0												
RECEP (UNDER 10 KVA)	0.0	100	0.0												
RECEP (EXCESS OF 10 KVA)	0.0	50	0.0												
HEAT	0.0	100	0.0												
MOTOR (LARGEST)	24.9	125	31.1												
MOTORS	37.8	100	37.8												
MISC. PANEL "L3G"	4.5	100	4.5												
MISC.	0.0	100	0.0												
MISC.	6.2	100	6.2												
TOTAL AFTER DEMAND LOADS PER PHASE:	A 26.6	B 26.6	C 26.6												
	TOTAL KVA	79.7													
	TOTAL AMPS	95.9													

MC+ ENGINEERING, LLC 8421 STACY DRIVE, FEDERAL HEIGHTS, CO 80260 (P) 303.589.6202															
480/277 VOLTS 3 PHASE, 4 WIRE PANEL			H3H			225 AMPS									
SURFACE		FLUSH	TYPE		EATON		AIC		14,000						
<input checked="" type="checkbox"/> EXISTING <input type="checkbox"/> NEW <input type="checkbox"/> M.C.B. <input type="checkbox"/> MAX ALLOWED THIS PNL															
<input checked="" type="checkbox"/> VOLT AMPS CCT BKR A B C															
DESCRIPTION															
LIGHTING: Inv lab	1000	1	2	100	7	1	2	1	RECEP: esha office						
LIGHTING: esha	1200	20	3	4	20	500	20	500	RECEP: esha classroom						
LIGHTING: Injek lab	1000	20	5	6	20	500	20	500	RECEP: esha office						
LIGHTING: in,restroom	1100	20	7	8	20	1000	20	1000	LIGHTING: heavy equip shop						
LIGHTING: diesel shop	1200	20	9	10	20	1000	20	1000	LIGHTING: tool,storage crib						
LIGHTING: heavy equip shop	1000	20	15	16	20	1000	20	1000	LIGHTING: dynometer shop						
LIGHTING: office	1000	20	19	20	20	500	20	500	MULTI.PV/PQST						
SPARE	20	9	10	20	20	1000	20	1000	TVSS						
SPARE	20	13	14	20	20	1000	20	1000	SPARE						
SPARE	20	15	16	20	20	1000	20	1000	SPARE						
SPARE	19	20	20	20	20	1000	20	1000	SPACE						
SPARE	21	22	22	20	20	1000	20	1000	SPACE						
SPARE	23	24	24	20	20	1000	20	1000	SPACE						
SPARE	27	28	28	20	20	1000	20	1000	SPACE						
"RTU"	125	2	3	2	20	1000	20	1000	"RTU"						
PANEL "L3H"	9249	70	31	32	125	125	20	20	SPARE						
45KVA TRANSFORMER	9360	33	34	34	33	33	20	20							
"RTU-5"	7750	40	37	38	30	4871	30	30	"RTU-7"						
	7750	40	37	38	30	4871	22.0MCA / 25MFS	22.0MCA / 25MFS							
	7750	39	40	40	39	4871	22.0MCA / 25MFS	22.0MCA / 25MFS							
	7750	31	41	42	3	4871	31	31	SPARE						
CONNECTED KVA															
LIGHTING	21.9	125	27.4												
RECEP (UNDER 10 KVA)	0.0	100	0.0												
RECEP (EXCESS OF 10 KVA)	0.0	50	0.0												
HEAT	0.0	100	0.0												
MOTOR (LARGEST)	23.3	125	29.1												
MOTORS	14.6	100	14.6												
MISC. PANEL "L3H"	26.8	100	26.8												
MISC.	0.0	100	0.0												
MISC.	1.2	100	1.2												
TOTAL AFTER DEMAND LOADS PER PHASE:	A 35.4	B 33.6	C 31.5												
	TOTAL KVA	100.5													
	TOTAL AMPS	121.0													